

CERTIFICATE

Certificate No.:



**CONFIDENCE
TESTING
LAB**

Report No.:

R09080302L03

Certificate of Conformity

About the Low Voltage Directive 2006/95/EC

Holder:

Guangzhou Siquande Lighting Co., Ltd.
4F, Building C, Xintang Commercial Park, Da Guan
Rd, Tianhe District, Guangzhou, Guangdong
Province, P. R. China

Product:

Power Distributor

Model / Type:

AT1216, AT1816, AT2X250-400A, AT2416, AT4816,
MIXPOWER-1, MIXPOWER-2, MIXPOWER48,
MIXPOWER24, AT1232, AT3032, ATH-6/12, ATH-4,
AT535, AT2000+combination

Technical data:

Input 400V~ 50/60Hz 400A Class I
Output: 1phase 250V~ 50/60Hz 40A
3phase 400V~ 50/60Hz 63A

Test acc. to:

EN 60439-1:1999
EN 60439-5:2006

This certificate of conformity is based on evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with the Low Voltage Directive 2006/95/EC. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex III of the Directive.

31. 08 . 2009

Date of issue
(Day/mo/yr)



Lab. Manager
Jim Lee

CFC Testing Laboratory
6F, 12 Jiangong Rd. Zhongshan Avenue West
Guangzhou, People's Republic of China
Tel: 86-20-85558836 Fax:86-20-85558699

